

Three Phase Transformer Pad Only!

Customer to provide transformer pad. Transformer Pad shall be 7' X 7' overall dimensions. Pad shall contain a 54" X 16" area for primary and secondary wire installation. Secondary shall fall in the 24" area specified as secondary on drawing below. Two 4" sweeping 90° elbows shall be installed on primary side for access to transformer. Access area centered 12" from front and 15" from sides of transformer pad. Transformer pad to be 6" thick min. 2500 lb. PSI concrete

